

**12.18.020.4 - Local limits.**

**A.**

The City is authorized to establish local limits pursuant of 40 CFR Part 403.5(c).

**B.**

The following pollutant limits are established to protect against pass through and interference. No person shall discharge wastewater containing in excess of the following (daily maximum limit):

160 <sup>(1)</sup> mg/L	Ammonia as N
0.11 mg/L	Arsenic (total recoverable)
1.0 mg/L	Benzene
220 mg/L	BOD <sub>5</sub>
0.05 mg/L	Cadmium (total recoverable)
0.27 mg/L	Chromium (total recoverable)
1.37 mg/L	Chloroform
0.65 mg/L	Copper (total recoverable)
0.29 mg/L	Cyanide (total)
0.3 mg/L	Lead (total recoverable)
0.005 mg/L	Mercury (total)
0.27 mg/L	Nickel (total recoverable)
90 mg/L	Oil and grease (total)
0.030 mg/L	Selenium (total recoverable)
0.25 mg/L	Silver (total recoverable)
0.35 mg/L	Sulfide (total as S)
1.0 mg/L	Tetrachloroethylene
1.0 mg/L	Toluene
430 mg/L	Total suspended solids
0.004 mg/L	Tributyltin
1.0 mg/L	Xylene
1.0 mg/L	Zinc (total recoverable)

<sup>(1)</sup> The local limit for West County Landfill leachate is 100 pounds per day (lb/day). All other industrial users must achieve a local limit of 160 mg/L.

The above limits apply at the point where the wastewater is discharged to the WPCP. The City Engineer may impose mass limitations in addition to the concentration-based limitations above.

**C.**

The City may develop BMPs, by ordinance or in an individual or general wastewater discharge permits, to implement local limits and the requirements of Section 12.18.020.1

(Ord. No. 18-11 N.S., § I, 7-26-2011)