



Richmond Fire Department Prevention Services Division



450 Civic Center Plaza · Richmond, CA 94804 · Phone (510) 307-8037 · Fax (510) 307-8048

FIRE EXTINGUISHER INFORMATION

**FIRE
& SAFETY
TRAINING**



ORDINARY
A
COMBUSTIBLES



FLAMMABLE
B
LIQUIDS



ELECTRICAL
C
EQUIPMENT

Here's What You Need To Know About Fire Extinguishers As A New Or Existing Business In The City of Richmond

General Guidelines

- You need to have a minimum 2-A:10-B:C rated fire extinguisher.
- Business (Restaurants) that use combustible cooking oils (vegetable or animal oils and fats) shall have a Class K extinguisher (silver in color).
- Extinguishers shall be installed so that the top of extinguisher is not more than five (5) feet above the floor.
- Extinguishers shall be conspicuously located where its readily accessible and free from visual obstructions (additional signage may be needed for compliance)

Inspection, Maintenance, and Recharging of Portable Fire Extinguishers

- The owner or designated agent or occupant of the property in which fire extinguisher are located shall be responsible for inspection, maintenance, and recharging.
- Extinguisher shall have a service tag placed on the front of the extinguisher that bears the label of the Office of the California State Fire Marshal approved testing laboratory.
- All fire extinguishers shall be subject to maintenance at intervals of not more than one (1) year.

Please be advised that other requirements may apply upon further inspection.

Local Fire Extinguisher/Fire Equipment Service Companies

International Fire Equipment
437 Ohio Avenue- Richmond, CA 94804
(510) 237-5000

Golden Gate Fire Equipment
728 38th Street - Richmond, CA 94802
(510) 234-7980

